



Order No. J20052639

July 5, 2001
Revised: November 2, 2001

REPORT NO. J20052639-004A

**FIELD IMPACT SOUND TRANSMISSION TEST
AND CLASSIFICATION OF FLOORING
OVER AN EIGHT INCH THICK CONCRETE
SLAB FLOOR/CEILING**

RENDERED TO

**MIDWEST PADDING
2500 OLD HADAR ROAD
PO BOX 2283
NORFOLK, NE 68702**

INTRODUCTION

This report gives the results of a Field Impact Sound Transmission test and Classification of flooring over an eight inch thick concrete slab floor/ceiling. The testing was performed in a multi-level building under construction located at 28099 Perdido Beach Blvd., Orange Beach, AL 36561.

AUTHORIZATION

Purchase Order No. 9216 from Midwest Padding.

TEST METHOD

The specimen was tested in accordance with the American Society for Testing and Materials designations ASTM E1007-97, "Standard Test Method for Field Measurement of Impact Sound Transmission Through Floor-Ceiling Assemblies and Associated Support Structures", and classified in accordance with ASTM E989-89 (Re-approved 1999), entitled, "Standard Classification for Determination of Impact Insulation Class (IIC)".

An Independent organization testing for safety, performance, and certification.

All services undertaken subject to the following general policy: Reports are submitted for exclusive use of the clients to whom they are addressed. Their significance is subject to the adequacy and representative character of the samples and to the comprehensiveness of the tests, examinations or surveys made. No quotations from reports or use of ITS' name is permitted except as expressly authorized by ITS in writing.

TEST METHOD – Cont'd.

The method is designed to measure the impact sound transmission performance of a floor-ceiling assembly and associated supporting structures in field situations. A standard tapping machine (B&K Type 3204) was placed at four positions on the test specimen which formed the horizontal separation between two rooms, one directly above the other. The data obtained was normalized to reference room absorption of 10 square meters in accordance with the test method.

The standard also prescribes a single-figure classification rating called "Field Impact Insulation Class, FIIC", which can be used by architects, builders, and code authorities for acoustical design purposes in building construction.

The FIIC is obtained by matching a standard reference contour to the plotted normalized one-third octave band sound pressure levels at each test frequency. The greater the FIIC rating, the lower the impact sound transmission through the floor-ceiling assembly.

DESCRIPTION OF TEST SPECIMEN

The test specimen consisted of 3/8 inch thick engineered tongue and groove wood planks directly glued to 1/8 inch thick Insulayment directly glued to the 8 inch thick post tension slab (4000 psi) concrete subfloor.

The description of the test specimen was supplied by the client.

The receiving room had a volume of approximately 61 m³ and contained surfaces of sheetrock, concrete and glass.

RESULTS OF TEST

The data obtained in the room below the panel normalized to $A_o = 10$ square meters, is as follows:

<u>1/3 Octave Band Center Frequency Hz</u>	<u>1/3 Octave Band Sound Pressure Level dB re 0.0002 Microbar</u>
100	52.9
125	57.9
160	56.7
200	56.8
250	52.9
315	54.8
400	53.5
500	54.1
630	51.9
800	44.2
1000	40.2
1250	37.6
1600	36.0
2000	31.5
2500	29.2
3150	24.9
Field Impact Insulation Class (FIIC)	60

REMARKS

Ambient Temperature: 86°F

Relative Humidity: 74%

Report No. J20052639-004A

Page 4 of 4

CONCLUSION

The test method employed for this test has no pass-fail criteria, therefore, the evaluation of the test results is left to the discretion of the client.

Date of Test: June 21, 2001

Report Approved by:



James R. Kline, Technician
Acoustical Testing

hkf